



STATE OF WISCONSIN

Department of Safety and Professional Services

INDUSTRY SERVICES DIVISION

Administrator's Office

P. O. Box 2658

Madison, Wisconsin 53701-2658

Governor Scott Walker

Secretary Dave Ross

TTY: Contact Through Relay

Wastewater Treatment

SPS 382.34(8) - 11/24/04

Can the runoff from an area under a fueling canopy be discharged to the sanitary sewer if the remainder of the site is discharged to the storm? Yes, however an oil and flammable liquids separator is required to serve the discharge from under the canopy.

SPS 382.34(11) - 11/24/04

Is a variance required for a meat processing plant discharge to bypass an interceptor if the state Department of Natural Resources has issued a Wastewater Pollutant Discharge Elimination System permit to land spread waste including the blood and other byproducts? No. Since the code states the reason for the requirement, i.e. "to prevent the discharge of feathers, entrails, blood and other materials" and the waste is not being "discharged," but is being collected and land spread, a variance would not be required in this instance.

SPS 382.50 - 6/1/04

Are there requirements beyond SPS 382.50 for laboratories? Yes, there are other requirements for laboratories. See the federal Center for Disease Control Web site for more information.